

Major Sacramento Regional Wastewater Treatment Plant (SRWTP) Spills

2004

There were no major spills at SRWTP in 2004.

2005

There were no major spills at SRWTP in 2005.

2006

There was only one major spill at the treatment plant in 2006. Approximately 955,000 gallons spilled from a broken process wash water pipeline. This process wash water is used throughout the facility for various purposes. There is a project in progress to assess and replace damaged sections of the line.

2007

There were no major spills at SRWTP in 2007.