

Major Sacramento Regional Wastewater Treatment Plant (SRWTP) Spills

SRWTP (2004-2009)	
Year	Description
2004	No major spills.
2005	No major spills.
2006	There was only one major spill at the treatment plant in 2006. Approximately 955,000 gallons spilled from a broken process wash water pipeline. This process wash water is used throughout the facility for various purposes. There is a project in progress to assess and replace damaged sections of the line.
2007	No major spills.
2008	No major spills.
2009	No major spills.